

Government Of West Bengal Office Of The Divisional Fire Officer Purulia West Bengal Fire & Emergency Services Purulia Fire Station, Ranchi Road, Purulia, Pin:- 723101

Memo no.:IND/WB/FES/20182019/20333

Date: 19-06-2023

From:

Divisional Fire Officer, Purulia West Bengal Fire & Emergency Services

To: Garh Panchakot International School Run Under Garh Panchakot Welfare Trust Sarbari More, P.O. P.S Neturia, over R.S Plot no. 140, 142, 143, 116, 204, 205, 206, 207, 208, 209, 210, 211, Mouza: Nawada, J.L. no.108, Dist, Purulia Pin - 723121.

Sub: The renewal of fire safety certificate for the occupancy of an existing G+1 storled school building under the group of educational at the premises "Garh Panchakot International School Run Under Garh Panchakot Welfare Trust" Is situated at Sarbari More, P.O.P.S. Neturia, over R.S. Plot no. 140, 142, 143, 116, 204, 205, 206, 207, 208, 209, 210, 211, Mouza: Nawada, J.L. no.108, Dist. Purulia Pin - 723121.

This is in reference to your application no. 0125191231600042 dated 06-06-2023 regarding the The renewal of fire safety certificate for the occupancy of an existing G+1 storied school building under the group of educational at the premises "Garh Penchakot International School Run Under Garh Panchakot Welfare Trust" is situated at Sarbari More. P.O.P.S. Neturia, over R.S Plot no. 140, 142, 143, 116, 204, 205, 206, 207, 208, 209, 210, 211, Wouze: Nawada, J.L. no. 108, Dist. Purulia Pn - 723121.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

- Driveway must be free of any type of obstruction for easy movement of fire appliances.
- 2. No parking shall be allowed on the driveway.
- 3. Existing electrical wring of the whole building shall be carefully checked is view of fire and life safety.
- 4. The employees and security staff shall be knowledged to the security staff shall be security staff shall the installed firefighting equipment of the building and operate it in the event of fire and testing.

5. Mock 'Ire practice and evacuation drills shall be

odically with the participation of all occupants of the

Rancipalned Donum H PANCHAKOT INTERNATIONAL SCHOOL

PURUI IA

Sah Ranchak

building.

- A crew of trained firefighting under the experienced officer shall be maintained around the clock for the safety of the building.
- 7. The arrangement shall be made for regular checking and testing for all the firefighting installations and equipment in the building to keep perfectly good working conditions at all times.
- 8. The fire safety audit is to be conducted at regular intervals and to be recorded in the fire prevention maintenance on the register.
- 9. Fire notice for firefighting and evacuation of the building shall be prepared and displayed in all vulnerable places of the building.
- 10. Any deviation and changes in the nature of the use of the building in respect of the submitted drawing plan of this building without obtaining prior permission from the office in this regard renewal of the fire safety certificate shall be treated as cancelled.
- 11. This renewal of the fire safety certificate shall remain valid for three years and shall be renewed before the expiry date.

Signature Not Verified

Divisional Fire Officer Purulia West Bengal Fire & Emergency Services

Jumba Bluttalinge

The control of the second line URL edistrict with any in and then obtains on the Vertianin park to the control of the second in the

Frabact Parcy Contito

PURULIA